

# EUROPEAN TELECOMMUNICATION STANDARD

ETS 300 119-3

January 1994

Source: ETSI TC-EE

ICS: 33.080

Key words: Equipment, racks, cabinets

Reference: DE/EE-3001.4

Equipment Engineering (EE); European telecommunication standard for equipment practice Part 3: Engineering requirements for miscellaneous racks and cabinets

# ETSI

European Telecommunications Standards Institute

# **ETSI Secretariat**

**Postal address:** F-06921 Sophia Antipolis CEDEX - FRANCE **Office address:** 650 Route des Lucioles - Sophia Antipolis - Valbonne - FRANCE **X.400:** c=fr, a=atlas, p=etsi, s=secretariat - **Internet:** secretariat@etsi.fr

Tel.: +33 92 94 42 00 - Fax: +33 93 65 47 16

**Copyright Notification:** No part may be reproduced except as authorized by written permission. The copyright and the foregoing restriction extend to reproduction in all media.

New presentation - see History box

Page 2 ETS 300 119-3: January 1994

Whilst every care has been taken in the preparation and publication of this document, errors in content, typographical or otherwise, may occur. If you have comments concerning its accuracy, please write to "ETSI Editing and Committee Support Dept." at the address shown on the title page.

# Contents

Forew	vord			5	
1	Scope			7	
2	Normativ	e referen	ces	7	
3	Dimensio 3.1 3.2 3.3 3.4	ons for mi Height Width Depth Other dir	scellaneous racks/cabinets		
4	Accessibility and line-up of miscellaneous racks/cabinets8				
5	Floor load 5.1 5.2 5.3	ding Weight p Weight p Point loa	per unit area of fully equipped miscellaneous rack/cabinet per unit area of cable support structure and cabling ading		
6	Structura 6.1 6.2	l load on Static loa Dynamic	a miscellaneous rack/cabinet ad b load		
7	External cable access				
8	Dimensions of packaged miscellaneous rack/cabinet9				
Annex	k A (inform	native):	Illustrative figures	12	
Annex B (informative): IEC Sub Committee 48D publication1					
Histor	<i>.</i> у				

Blank page

# Foreword

This European Telecommunication Standard (ETS) has been produced by the Equipment Engineering (EE) Technical Committee of the European Telecommunications Standards Institute (ETSI).

This ETS is part 3 of a 4 part ETS aimed at setting out, on a common basis, the installation engineering requirements for telecommunication practice, for housing equipment forming part of a public telecommunications network.

Part 1 is a general introduction, and explains the terminology used, Part 2 specifies the engineering requirements for racks and cabinets. This part, Part 3, specifies the engineering requirements for miscellaneous racks and cabinets, Part 4 covers engineering requirements for subracks in miscellaneous racks and cabinets.

This ETS applies to all telecommunication equipment forming part of the public telecommunications network. The requirements for miscellaneous racks and cabinets which this part lays down are based on the work of IEC Sub Committee 48D (see Annex B).

Illustrative figures are contained in Annex A.

Blank page

# 1 Scope

This part of European Telecommunication Standard (ETS) 300 119 details requirements for miscellaneous racks and cabinets supplied unequipped. The miscellaneous racks/cabinets shall be used for housing telecommunication equipment forming part of a public telecommunication network installed either on the public telecommunication operators' sites or in the premises of operator's customers. The miscellaneous racks/cabinets shall be able to accommodate various equipments, e.g. subracks (see ETS 300 119-4 [3]) and shall have provision for doors or covers.

Part 1 of this ETS (ETS 300 119-1 [1]) defines the meaning of rack or cabinet in the context of this ETS.

# 2 Normative references

This ETS incorporates by dated or undated reference, provisions from other publications. These normative references are cited at the appropriate places in the text and the publications are listed hereafter. For dated references, subsequent amendments to or revisions of any of these publications apply to this ETS only when incorporated in it by amendment or revision. For undated references the latest edition of the publication referred to applies.

- [1] ETS 300 119-1: "Equipment Engineering (EE); European telecommunication standard for equipment practice Part 1: Introduction and terminology".
- [2] ETS 300 119-2: "Equipment Engineering (EE); European telecommunication standard for equipment practice Part 2: Engineering requirements for racks and cabinets".
- [3] ETS 300 119-4: "Equipment Engineering (EE); European telecommunication standard for equipment practice Part 4: Engineering requirements for subracks in miscellaneous racks and cabinets".

# 3 Dimensions for miscellaneous racks/cabinets

#### 3.1 Height

The height dimension (H) includes covers, feet or castors if these are an integral part of the miscellaneous rack/cabinet structure.

For telecommunication centres and customer sites, H shall be 2 200 mm.

The miscellaneous rack/cabinet shall have provision within its height for the attachment of parts for interfacing to any overhead structure.

The miscellaneous racks/cabinets shall also be provided with devices which can be height-adjusted to compensate for any unevenness in the floor. The scope for height adjustment shall be at least 25 mm. The nominal miscellaneous rack/cabinet height shall be measured when the adjustment devices are at their fully retracted positions.

#### 3.2 Width

The width dimension (W) includes covers if they are an integral part of the miscellaneous rack/cabinet.

W shall be 600 mm.

The sides of any miscellaneous rack/cabinet shall not interfere with the assembly of adjacent racks/cabinets (into a straight line-up). The suppliers shall ensure that the miscellaneous rack/cabinet will fit into the space between the grid lines, as illustrated in Annex A, figure A.1. Manufacturing tolerances shall therefore be so arranged that this objective will always be achieved, even when miscellaneous racks/cabinets are delivered from different suppliers.

# Page 8 ETS 300 119-3: January 1994

NOTE: If additional equipment at the end(s) of a suite of miscellaneous racks/cabinets is required the associated coordination dimensions shall be specified as an integer multiple of the mounting pitch of 25 mm for each side during equipment practice design and should be agreed between supplier and user.

#### 3.3 Depth

The depth dimension (D) includes:

- a) doors or covers of the miscellaneous rack/cabinet structure if present;
- b) protruding parts e.g. switches, lamps, hinges, locks, electro-static discharge points, etc.;
- c) connectors, cabling, cooling fins, etc.

For the doors or covers a minimum reference value for aisle width shall be 750 mm. Doors or covers which are in the open position shall protrude from the front/rear line of miscellaneous racks/cabinets by a maximum of 150 mm. Doors or covers shall be designed so that when open, they do not in any way restrict access to the equipment for essential maintenance and installation operations in that rack or cabinet.

D shall be 300 mm or 600 mm.

#### 3.4 Other dimensions

For other dimensions of the miscellaneous rack/cabinet, see table 1 and refer to Annex A figures A.3, and A.4.

# 4 Accessibility and line-up of miscellaneous racks/cabinets

Miscellaneous racks/cabinets of different depths may be used in any rack/cabinet line-up, but the front line of all racks/cabinets shall be aligned as illustrated in Annex A, figure A.2. Racks/cabinets with a depth of 300 mm shall be accessed only from the front, to allow them to be placed back-to-back or to the wall.

The front line of miscellaneous racks/cabinets arranged back to back shall be aligned to the rear line (see Annex A, figure A.2).

# 5 Floor loading

The maximum permissible miscellaneous rack/cabinet weight depends on the miscellaneous rack's/cabinet's floor area. To calculate weight per unit area in kN/m2, the actual weight of the miscellaneous rack/cabinet should be divided by the floor area (W x D of the rack/cabinet). The weight per unit area added by the overhead support structure and cabling is also calculated by using the floor area of the supporting miscellaneous rack/cabinet.

The arrangement of miscellaneous racks/cabinets has to be planned by the installer to ensure that the average floor loading for a building is not exceeded. This will be a lower value than the weight per unit area and will depend, for example, on the centre distance of the rack/cabinet rows.

#### 5.1 Weight per unit area of fully equipped miscellaneous rack/cabinet

For general applications the weight per unit area fully equipped miscellaneous rack/cabinet, including internal cabling, etc., should not exceed 15 kN/m<sup>2</sup>. The maximum allowed weight per unit area shall be 20 kN/m2.

#### 5.2 Weight per unit area of cable support structure and cabling

The weight per unit area exerted by the relevant portions of the cable support structure with cabling, should usually not exceed  $3 \text{ kN/m}^2$ . The maximum allowed weight per unit area shall be  $8 \text{ kN/m}^2$ .

#### 5.3 Point loading

A point loading exerted by the base of the fully equipped miscellaneous rack/cabinet on the floor shall not exceed 490 N/cm<sup>2</sup>.

NOTE: Other values for point loading may be adopted by agreement between the supplier and customer.

# 6 Structural load on a miscellaneous rack/cabinet

#### 6.1 Static load

The miscellaneous rack/cabinet shall be able to support a static load of the superstructure with cabling, as described in Clause 5.

#### 6.2 Dynamic load

During installation, the miscellaneous rack/cabinet shall support an additional load of 800 N for a miscellaneous rack/cabinet of 600 mm x 600 mm and 400 N for a miscellaneous rack/cabinet of 600 mm x 300 mm

# 7 External cable access

The miscellaneous rack/cabinet design shall enable the cabling for the telecommunication equipment to be routed either over a cable support structure, or under a raised floor, as required i.e. cable access shall be provided in both top and bottom of the miscellaneous rack/cabinet

Direct miscellaneous rack/cabinet to miscellaneous rack/cabinet cabling is also allowed within rows.

External cables shall be located in the area on the left and right hand sides of the miscellaneous rack/cabinet, between the subrack and miscellaneous rack/cabinet structure.

The minimum area for cable shall be 6 000 mm2 on each side. This figure is based on the use of a 500 mm wide subrack. The area available will increase when a 450 mm wide subrack is installed.

# 8 Dimensions of packaged miscellaneous rack/cabinet

The maximum dimensions of a packaged miscellaneous rack/cabinet shall not exceed

2 500 mm x 1 200 mm x 900 mm.

These maximum dimensions are stated to allow transportation when using normal lifts, hallways and doors.

#### Page 10 ETS 300 119-3: January 1994

Table 1

(see also Annex A, figures A.3 and A.4)

Dimensions in mm.

	Dimensions for miscellaneous racks/cabinets	(NOTE 3)	600x300	600x600
H =heig	ht	С	2200	2200
W =	width	С	600	600
D =	depth (NOTE 5)	С	300	600
H1 =	mounting height aperture	С	2000 (NOTE 1)	
W1 =	mounting width aperture	С	535	535
W2 =	aperture between mounting flanges	С	500	500
W3 =	mounting centre distance e.g. for subracks	А	515	515
D1 =	mounting depth aperture (front) (NOTE 5)	С	40	75
D2 =	mounting depth aperture (rear) (NOTE 5)	С	240	470
R =mou	nting position	С	12,5	12,5
S =mou	nting pitch	А	25	25
F = faste	ening points	А	(NOTE 2)	
D3 =	mounting depth aperture i.e. for possible front cover/door (NOTES 4,5)	С	10	25
D4 =	mounting depth aperture i.e. for possible rear cover/door (NOTES 4,5)	С	5	25

(continued)

# Table 1 (concluded)

NOTE	<ol> <li>Miscellaneous rack/cabinet designs of aperture height 2 000 + n x 25 are allowed, but are not a requirement.</li> </ol>
NOTE	2: Fastening points, metric screw thread M6 to be used.
NOTE	3: A = Actual dimension. Tolerances needed for W3 and S are specified in IEC 917-2-1 (see Annex B).
NOTE	<ul> <li>C = Coordination dimension.</li> <li>4: Depth D3 applies to aperture width W1.</li> </ul>
NOTE	<ul> <li>5: The difference, 5 mm, between D, 300 mm, and the sum of D1, D2, D3 and D4, 295 mm, is the allowance for miscellaneous rack/cabinet construction, manufacturing tolerances and clearance for installing subracks.</li> </ul>
	A similar explanation applies to the 600 mm deep miscellaneous rack/cabinet.
Definition:	A coordination dimension is a reference dimension used to coordinate mechanical interfaces. This is not a manufacturing dimension with a tolerance.
	An aperture dimension is a special coordination dimension for a usable space between features.
	An actual outside dimension corresponding to a coordination dimension can only decrease.
	An actual inside dimension corresponding to an aperture dimension can only increase.

Page 12 ETS 300 119-3: January 1994

Annex A (informative): Illustrative figures



Figure A.1



Figure A.2: Possible floor arrangement (example)



Figure A.3: Miscellaneous rack/cabinet



\* Space to be available for equipment, e.g. subracks

Figure A.4: Miscellaneous rack/cabinet

# Annex B (informative): IEC Sub Committee 48D publication

This ETS is based on the following standard:

"Modular order for the development of mechanical structures for electronic equipment practices. IEC 917-2: Sectional standard: Interface co-ordination dimensions for the 25 mm equipment practice".

IEC 917-2-1 is currently following approval procedure as IEC 48D(CO)31.

# History

Document history				
January 1994	First Edition			
February 1996	Converted into Adobe Acrobat Portable Document Format (PDF)			